

Contact:
Isamu Kawano
Takahiro Tanaka

142 Charcot Avenue,
San Jose, CA,
95131, U.S.A.

Tabuchi Electric Company of America
Phone: 408-224-9300

**Tabuchi Electric
Company of America**

Addendum

Addendum for Installation Precautions of EIBS Battery unit

Lithium-ion Battery Storage Unit : EOW-LB100-PNUS and EOW-LB100-PNUS2

For Hybrid Inverter : THD-S55P3B-US, THD-S55P3BB-US (MM2018-0011)

This is an addendum for understanding the installation requirements in "Installation Precaution".

1. Installation in an open garage is allowed, as long as the battery(ies) is/are not exposed to direct rain.
2. Clearances and ventilation are recommended but not mandatory, as long as the battery breaker is accessible.
3. Battery can be installed indoors and/or outdoors in an enclosure without clearances as long as the battery breaker is accessible.

Please contact us if you have a question about this supplementation or installation requirement.